

Decentral Smart Grid Control

This content has been downloaded from IOPscience. Please scroll down to see the full text.

2015 New J. Phys. 17 015002

(<http://iopscience.iop.org/1367-2630/17/1/015002>)

View [the table of contents for this issue](#), or go to the [journal homepage](#) for more

Download details:

IP Address: 134.76.162.165

This content was downloaded on 25/08/2016 at 09:38

Please note that [terms and conditions apply](#).

You may also be interested in:

[Focus on networks, energy and the economy](#)

Marc Timme, Ljupco Kocarev and Dirk Witthaut

[Comparative analysis of existing models for power-grid synchronization](#)

Takashi Nishikawa and Adilson E Motter

[Short term fluctuations of wind and solar power systems](#)

M Anvari, G Lohmann, M Wächter et al.

[Community consistency determines the stability transition window of power-grid nodes](#)

Heetae Kim, Sang Hoon Lee and Petter Holme

[Synchronization of weakly coupled oscillators: coupling, delay and topology](#)

Enrique Mallada and Ao Tang

[Improving power grid transient stability by plug-in electric vehicles](#)

Andrej Gajduk, Mirko Todorovski, Juergen Kurths et al.

[The delayed and noisy nervous system: implications for neural control](#)

John G Milton

New Journal of Physics

The open access journal at the forefront of physics

Deutsche Physikalische Gesellschaft  DPG
IOP Institute of Physics

Published in partnership
with: Deutsche Physikalische
Gesellschaft and the Institute
of Physics



CORRIGENDUM

Corrigendum: Decentral smart grid control (2015 *New J. Phys.* **17** 015002)

OPEN ACCESS

RECEIVED
5 May 2015

ACCEPTED FOR PUBLICATION
5 May 2015

PUBLISHED
22 May 2015

Content from this work
may be used under the
terms of the [Creative
Commons Attribution 3.0
licence](#).

Any further distribution of
this work must maintain
attribution to the
author(s) and the title of
the work, journal citation
and DOI.



Benjamin Schäfer¹, Moritz Matthiae¹, Marc Timme^{1,2} and Dirk Witthaut^{1,3,4}

¹ Network Dynamics, Max Planck Institute for Dynamics and Self-Organization (MPI DS), 37077 Göttingen, Germany

² Institute for Nonlinear Dynamics, Faculty of Physics, University of Göttingen, 37077 Göttingen, Germany

³ Forschungszentrum Jülich, Institute for Energy and Climate Research (IEK-STE), 52428 Jülich, Germany

⁴ Institute for Theoretical Physics, University of Cologne, 50937 Köln, Germany

E-mail: timme@nld.ds.mpg.de

The original manuscript (Schaefer *et al* 2015 *New J. Phys.* **17** 015002) contains three typographical errors that we have corrected below. The scientific results were not affected by the typographical errors and all numerical simulations were carried out using the correct equations.

1. Demand response via decentral smart grid control

Equation (1) should read

$$M_j \frac{d^2 \theta_j}{dt^2} + \kappa_j \frac{d\theta_j}{dt} = P_j^{\text{mech}}(t) + \sum_{k=1}^N K_{jk} \sin(\theta_k - \theta_j), \quad (1)$$

i.e., there is a '+' sign in front of the sum.

4. Dynamics and stability

4.3. Delayed adaptation: risks from resonances

Equation (31) should read

$$\tau = \frac{\arccos(-\alpha/\gamma)}{\text{Im}(\lambda)} + \frac{2\pi}{\text{Im}(\lambda)} n, \quad n \in \mathbb{N}. \quad (2)$$

This does not change the periodicity of the solution since $\text{Im}(\lambda)$ is constant and not a function of τ .

4.4. Stabilization by averaging

Finally, equation (34) should read

$$p(\lambda) = \lambda^2 + \alpha\lambda + 2K\sqrt{1 - \frac{P^2}{K^2}} + \frac{\gamma}{T} (e^{-\lambda\tau} - e^{-\lambda(T+\tau)}) = 0. \quad (3)$$

The original equation used an erroneous minus sign.



PAPER

Decentral Smart Grid Control

OPEN ACCESS

RECEIVED

22 August 2014

ACCEPTED FOR PUBLICATION

19 November 2014

PUBLISHED

9 January 2015

Content from this work
may be used under the
terms of the [Creative
Commons Attribution 3.0
licence](#).

Any further distribution of
this work must maintain
attribution to the author
(s) and the title of the
work, journal citation and
DOI.

Benjamin Schäfer¹, Moritz Matthiae¹, Marc Timme^{1,2} and Dirk Witthaut^{1,3,4}¹ Network Dynamics, Max Planck Institute for Dynamics and Self-Organization (MPIDS), D-37077 Göttingen, Germany² Institute for Nonlinear Dynamics, Faculty of Physics, University of Göttingen, D-37077 Göttingen, Germany³ Forschungszentrum Jülich, Institute for Energy and Climate Research (IEK-STE), D-52428 Jülich, Germany⁴ Institute for Theoretical Physics, University of Cologne, D-50937 Köln, GermanyE-mail: timme@nld.ds.mpg.de**Keywords:** Decentral Smart Grid Control, dynamic demand response, delayed coupling, oscillator networks, econophysics, transient stability, frequency-price coupling**Abstract**

Stable operation of complex flow and transportation networks requires balanced supply and demand. For the operation of electric power grids—due to their increasing fraction of renewable energy sources—a pressing challenge is to fit the fluctuations in decentralized supply to the distributed and temporally varying demands. To achieve this goal, common *smart grid* concepts suggest to collect consumer demand data, centrally evaluate them given current supply and send price information back to customers for them to decide about usage. Besides restrictions regarding cyber security, privacy protection and large required investments, it remains unclear how such central smart grid options guarantee overall stability. Here we propose a Decentral Smart Grid Control, where the price is directly linked to the local grid frequency at each customer. The grid frequency provides all necessary information about the current power balance such that it is sufficient to match supply and demand without the need for a centralized IT infrastructure. We analyze the performance and the dynamical stability of the power grid with such a control system. Our results suggest that the proposed Decentral Smart Grid Control is feasible independent of effective measurement delays, if frequencies are averaged over sufficiently large time intervals.

1. Introduction

A major challenge in realizing a future sustainable power supply is the volatile character of many renewable sources [1–3]. The power generation of wind turbines and photovoltaics fluctuates strongly on different time scales: in addition to the obvious variations between the seasons and during a single day [4], strong fluctuations occur on much shorter time scales, for instance due to the turbulent character of wind [5]. To match generation and demand in a fully renewable power grid for the current demand characteristics at every point of time, would thus require large storage facilities. Current estimates for the storage capacity range up to 400 TWh for the entire European grid with 100% renewables and no stand-by power plants [4]. In addition to potential environmental effects, as, e.g., the large landscape consumption for pumped hydro storage facilities, this would require massive capital investments.

To reduce these enormous numbers, it has been proposed to regulate the consumer *demand* to match the fluctuating power generation [6]. This is a massive paradigm shift in the operation of power grids, as mainly the generation is regulated in current power grids [7, 8]. In the new system, the price of electric energy shall be adapted to the current generation to provide a stimulus for the consumers to adapt their demand. Most proposals for such a *smart grid* are based on a sophisticated information and communication technology infrastructure. All ‘smart’ power meters communicate with a central computer in order to negotiate the price and control their demand (see, e.g., [9]). However, such a centralized system would also raise questions of cyber security and privacy protection [10, 11]. Even more, it has been shown that interdependent systems, such as this, can become vulnerable to cascading failures [10, 12].

An alternative, decentralized approach has been first proposed already years ago, but received a major interest only recently. The key idea is that the grid frequency provides all information needed to control the grid. The frequency increases in times of excess generation, while it decreases in times of underproduction [13, 14]. In current power grids, the primary control of conventional power plants is already based on the frequency: generation is increased when the frequency decreases and vice versa [15]. In a future, fully renewable grid the consumers could take over this role and regulate their demand autonomously on the basis of the grid frequency. To make this economically favorable, it was proposed that the price of electric energy for each local consumer is a direct function of the local grid frequency [16]. Is such a decentralized approach capable of ensuring stable network dynamics?

Here we analyze systems with prices locally computed as a direct function of local frequency, taking into account averaging time intervals and effective time delays. We demonstrate that the approach holds risks at certain time delays if the averaging interval is short. Intriguingly, for sufficiently large averaging interval, network dynamics is stable, independent of the delays. Our modeling results thus suggest that Decentral Smart Grid Control provides an efficient measure of ensuring grid stability.

The article is structured as follows. First, we introduce a mathematical model for the frequency dynamics of a power grid, describe our concept of a Decentral Smart Grid Control to realize the dynamic demand response (DR) in section 2 and discuss several economic aspects in section 3. The dynamics and stability of a fully interdependent techno-economical system are then analyzed in detail in section 4. We uncover potential systemic risks and show how they can be mastered by a proper implementation of the control.

2. DR via Decentral Smart Grid Control

DR is generally based on a flexible consumer price for electric power which is adapted to the current power generation. In periods of higher demand than generation, prices are high, giving an incentive to the consumers to reduce their consumption. Current approaches for the implementation of DR are mostly based on centralized information and communication infrastructure [8, 9], i.e., all information about production and consumption is collected decentralized, transmitted to one central IT-unit which then sends commands for further consumption and production to the decentralized actors. Such a system would require large financial investments and raises concerns about data protection and system vulnerability [10–12]. However, such an expensive IT-infrastructure may not be needed, as the grid frequency already encodes the necessary information and is accessible everywhere in the grid.

To analyze the essential frequency dynamics of a large-scale power grid and its coupling to pricing information we consider an oscillator model based on the physics of coupled synchronous generators and synchronous motors, which recently attracted a strong interest in physics [17–23]. This model is very similar to the ‘classical model [15] and the structure preserving model [24] from power engineering, which are routinely used to simulate the dynamics of power grids on coarse scales.

The state of each rotatory machine j is characterized by the rotor angle $\theta_j(t)$ relative to the grid reference rotating at $\Omega = 2\pi \times 50$ Hz or $\Omega = 2\pi \times 60$ Hz, respectively, and its angular frequency deviation from the reference $\omega_j = d\theta_j/dt$. Every machine has its moment of inertia M_j and is driven by a mechanical power $P_j^{\text{mech}}(t)$, which is positive for a generator and negative for a consumer. In addition, every machine is driven by the electric power transmitted via the adjacent transmission lines which have a coupling strength K_{jk} . The dynamics of the machine j is then given by the equation of motion as

$$M_j \frac{d^2\theta_j}{dt^2} + \kappa_j \frac{d\theta_j}{dt} = P_j^{\text{mech}}(t) - \sum_{k=1}^N K_{jk} \sin(\theta_k - \theta_j). \quad (1)$$

For a more detailed discussion and short derivation of the equations of motion, see appendix A.

For the sake of simplicity, we assume that all damping constants $\kappa_j = \kappa$ and moments of inertia $M_j = M$ are identical for a while. The overall angular frequency deviation $\langle\omega\rangle := \frac{1}{N} \sum_j \omega_j$ is then determined by the equation of motion

$$M \frac{d}{dt} \langle\omega\rangle + \kappa \langle\omega\rangle = \frac{1}{N} \Delta P, \quad (2)$$

where $\Delta P = \sum_j P_j^{\text{mech}}$ is the total power balance in the grid. Equation (2) can be solved analytically with the result

$$\langle \omega \rangle (t) = \langle \omega \rangle (t_0) e^{-\kappa t/M} + \frac{\Delta P}{N\kappa} (1 - e^{-\kappa t/M}). \quad (3)$$

For $t \rightarrow \infty$, the overall angular frequency deviation $\langle \omega \rangle$ converges to the value $\frac{\Delta P}{N\kappa}$. This relaxation is typically fast; most perturbations are cleared in less than a second [15]. In weakly connected grids inter-area oscillations can last for a minute [3, 26]. Hence, the angular frequency deviation $\langle \omega \rangle$ is directly proportional to the power balance of the entire system. In general, the angular frequency is the same throughout the grid $\omega_j = \langle \omega \rangle$ and can easily be measured, such that it can be used to control the grid without additional communication infrastructure.

The missing step to realize a Decentral Smart Grid Control is to come up with a one-to-one relation between the local grid angular frequency deviation ω_j and the current electricity price $p_j(\omega_j)$. A device that measures the local grid angular frequency and calculates the current price according to this pre-defined function $p_j(\omega_j)$ is cheap and can be implemented in a decentralized way, see [28] for large-scale frequency monitoring. Electric devices with an on-off load characteristic (e.g. washing, refrigeration, thermal heat pumps, electric cars) could automatically shift their consumption to times of high grid frequency, relieving the grid in low frequency times. Ensured by a properly chosen price function $p(\omega)$, this grid service can be economically reasonable for the consumer and also for the electricity provider, because the grid operator would have potentially less costs for primary, secondary and tertiary control. A drastic price increase at low frequencies and cheap electricity at high frequencies might also change the active consumer behavior. The needed technology is readily available, since micro combined heat and power systems or photovoltaic systems, already have a comparable control system included [8, 27].

In particular, we propose a Decentral Smart Grid Control that realizes a dynamic DR in power grids and analyze some of its core economic and dynamic consequences. The mechanical power $P_j^{\text{mech}}(t)$ in the equation of motion (1) is the difference of the generated and consumed power at the j th node of the network. Both generation and consumption depend on the current energy price p , which is described by supply $S(p)$ and demand curves $D(p)$, such that we find

$$P_j^{\text{mech}}(t) = S_j(p_j(t)) - D_j(p_j(t)). \quad (4)$$

A supply function $S(p)$ gives the amounts of goods offered, if this good is traded for a certain price p . Here, this is the amount of power supplied by a generator, if the obtained price is p . Similarly, the demand $D(p)$ gives the amount of power a consumer would like to consume for a given price p . Generally, the supply curve is monotonically increasing with p , while the demand curve is monotonically decreasing. The two curves are exogenous to the model, in fact they are determined by the strategy of the generators, the weather and the preferences of the consumers.

We suggest a Decentral Smart Grid Control that calculates the price on the basis of the local angular frequency deviation ω_j [16]; but measuring and updating the angular frequency in a real grid takes a certain time. Therefore, the price generally depends on a time-averaged angular frequency deviation $\bar{\omega}_j(t)$. Assuming that the angular velocity is measured over an interval of fixed period length T , we define

$$\bar{\omega}_j(t) = \frac{1}{T} \int_{t-T}^t \omega_j(t') dt'. \quad (5)$$

We consider two technical scenarios for the control. First, we consider a control system that adapts only in discrete time steps of length T such that the local prices are given by

$$p_j := p(\bar{\omega}_j(\lfloor t/T \rfloor T)), \quad (6)$$

where $\lfloor \cdot \rfloor$ denotes rounding towards minus infinity. Second, it can take a certain delay time τ until the control system adapts such that the local prices are given by

$$p_j := p(\bar{\omega}_j(t - \tau)). \quad (7)$$

We assume that the price only depends on the frequency and that supply and demand curves are given and keep their form on the time scales (seconds) described in this article. Hence, the design of an appropriate price function $p(\bar{\omega})$ is an important step for the implementation of a DR via Decentral Smart Grid Control.

3. Economic aspects

3.1. Benefits of DR

DR may have huge benefits in future energy systems see, e.g., [7, 8, 25, 29, 30]. Here, we briefly summarize the most important economic aspects, following [7], which hold regardless of the technical implementation: (1)

consumers may reduce their electricity bill by shifting their demand to periods of low prices. (2) In addition, DR may reduce the global costs of the power system as it allows for a more efficient use of the existing infrastructure and avoids costs for additional infrastructure. (3) DR may improve system stability by avoiding dangerous peaks of the demand and thus reduce the probability of power outages. (4) Finally, DR may improve market performance and reduce the price volatility. In addition to these points, DR is particularly important for future power grids because its implementation can potentially allow a higher penetration with renewable energies [31].

3.2. The grid as a market

In the current proposal of a Decentral Smart Grid Control there is no central computer which controls the demand of the consumers and no central exchange to determine the electricity price. The control is realized in a decentralized way using local frequency measurements, thus requiring no long-distance communication. Is this sufficient to provide an efficient market, i.e., to reach an economic equilibrium?

To answer this question we first note that the stable stationary operation of a power grid requires that all machines rotate in synchrony, i.e., the frequency must be the same everywhere

$$\omega_j(t) \stackrel{!}{=} \langle \omega \rangle \quad \text{for all } j \in \{1, \dots, N\}. \quad (8)$$

Otherwise the power flow between two nodes j and k

$$P_{jk}(t) = K_{jk} \sin(\theta_k(t) - \theta_j(t)), \quad (9)$$

would be oscillating and average out over time. The synchronous state must be dynamically stable for small disturbances to be damped out [15, 32] and the grid may self-organize to a synchronous state with steady power flows [18, 22, 33]. Substituting the condition $\omega_j(t) = \langle \omega \rangle$ into the equations of motion (1) shows that the synchronous state is determined by the equation

$$\kappa_j \langle \omega \rangle = S_j(p_j) - D_j(p_j) - \sum_{k=1}^N K_{jk} \sin(\theta_k - \theta_j) \quad \text{for all } j \in \{1, \dots, N\}. \quad (10)$$

Summing up the equations for all j and using $K_{ij} = K_{ji}$ yields

$$\sum_j S_j(p_j) = \sum_j D_j(p_j) + \sum_j \kappa_j \langle \omega \rangle. \quad (11)$$

This shows that a dynamical equilibrium of the grid also implies the economic equilibrium of the market, i.e., the supply equals the demand including transmission losses. Hence, we have to analyze the dynamic stability of the combined techno-economical system to evaluate its stability properties. This will be done in detail in section 4.

For now, we assume that the grid is in equilibrium with $\langle \omega \rangle = 0$ at a price p_Ω . To analyze the stability of this equilibrium, we linearize the supply and demand curves close to the equilibrium:

$$\begin{aligned} S_j(p_j) &= S_j(p_\Omega) + \underbrace{\frac{dS_j}{dp}}_{=: s_j} \Big|_{p_\Omega} (p_j - p_\Omega) \\ D_j(p_j) &= D_j(p_\Omega) + \underbrace{\frac{dD_j}{dp}}_{=: d_j} \Big|_{p_\Omega} (p_j - p_\Omega). \end{aligned} \quad (12)$$


The modeling or measurement of supply and demand curves then reduces to the measurement of the elasticity of supply and demand. Generally, the supply increases with the price while the demand decreases such that $s_j \geq 0$ and $d_j \leq 0$ and thus in particular

$$s_j - d_j > 0 \quad \text{for all } j. \quad (13)$$

Here, we used course-graining, i.e., not every consumer is represented by one demand function but several consumers are aggregated to form one node in the network and hence supply and demand curves are assumed to be smooth.

3.3. Price and frequency fluctuations

The new aspect of our proposal of a Decentral Smart Grid Control is the direct encoding of the electricity price in the grid frequency. Thus, the grid frequency must be allowed to vary in certain boundaries so that fluctuations of



the price are directly related to fluctuations of the frequency. Currently, frequency variations are limited due to technical reasons [34]. In the European grid ± 200 mHz are acceptable in normal operation and up to ± 800 mHz can occur in extreme cases for short times before emergency measures such as load shedding are initiated [35]. This sets the order of magnitude at which the frequency may vary. Accordingly, we consider a frequency range of (50 ± 0.5) Hz.

In figure 1 we analyze the possible variations of the price and the frequency in more detail. Panel (a) shows a histogram of plausible values of the consumer price, if this price is strictly coupled to the variable spot market price for Germany in 2012 [36]. To obtain plausible consumer prices, we add 9 ct kWh^{-1} for distribution and service, 7 ct kWh^{-1} fees plus 19% VAT on the total. The variations of the electricity price directly relate to variations of the grid frequency as described above. We consider a linear price curve for all nodes

$$p(\bar{\omega}_j) = p_\Omega - \epsilon \times \bar{\omega}_j, \quad (14)$$

with $p_\Omega = 24.1 \text{ ct kWh}^{-1}$, as shown in panel (b1). For a slope $\epsilon = 10 \text{ (ct kWh}^{-1})/2\pi \text{ Hz}$, the price curve maps the operational range $(\bar{\omega}_j + \Omega)/2\pi \in [49.5, 50.5]$ Hz to a price interval $p \in [19.1, 29.1] \text{ ct kWh}^{-1}$, which covers 98% of the observed fictitious consumer prices. A histogram of the resulting frequency variations is shown in panel (c1). In 2% of all time slots prices outside of this interval were recorded which can even become negative.

To treat such events accordingly, a nonlinear function must be chosen which maps a fixed finite frequency interval to all possible prices, i.e., to the real line. Still, the slope of this function should be bounded around the operational point $\Omega = 50$ Hz. These requirements are satisfied by an inverse sigmoidal function. As a particular example, we here consider the function

$$p(\bar{\omega}_j) = p_\Omega - \frac{\alpha}{2} \tanh^{-1}\left(\frac{\bar{\omega}_j}{\pi\beta}\right), \quad (15)$$

which maps all angular frequency deviations in the interval $\bar{\omega}_j \in (-\pi\beta, +\pi\beta)$ to a price $p \in (-\infty, +\infty)$. The operational range can thus be fixed beforehand, and emergency measures can be specified, if frequencies outside this range are measured. Choosing $\alpha = \beta\epsilon$ yields the same slope of the price curve around the reference frequency as the linear price function (14). Indeed, using $\beta = 1 \text{ Hz}$ the statistics of the observed frequencies in figure 1 hardly change in comparison to the linear price function, see panels (b2) and (c2). The corresponding frequencies change significantly only for extreme price events, which now map to the operational range $(\bar{\omega}_j + \Omega)/2\pi \in [49.5, 50.5]$ Hz as desired. A similar statistic is found for other sigmoidal functions. The precise form of such a nonlinear price function can be designed by the grid operators on the basis of actual market and consumption data.

We note that figure 1 is based on the German spot market prices, which show huge fluctuations compared to other energy markets [39]. Furthermore, one major effect of a comprehensive DR would be to suppress extreme

price fluctuations anyway [7, 14]. Hence, we expect that the fluctuations shown in the figure represent extremes, and that they would be significantly smaller in energy systems with DR and (virtual) storage.

4. Dynamics and stability

Dynamical stability is a basic requirement for power grid operation [3, 15]. For DR via Decentral Smart Grid Control, a stable dynamic equilibrium ensures that the energy system is also in an economic equilibrium as shown above. However, stability properties may become much more involved due to the interdependency of the technical and the economical subsystem. Interdependencies may introduce new systemic risks to dynamical network systems [12, 37].

The interaction of the DR system with the grid depends crucially on their time scales. In contrast to current energy markets, the price can be adapted in almost real time, limited only by the time needed for a frequency measurement. Here, we analyze the dynamical stability of the full techno-economic system and identify new systemic risks for different scenarios and discuss how to master these risks.

4.1. Instantaneous adaption

We first investigate a DR that is fast compared to the grid dynamics. Assuming an instantaneous adaption of the demand, i.e., $T = \tau = 0$ in equations (6) and (7), the effective power $P_j^{\text{mech}}(t)$ in equation (1) becomes a function of the current angular frequency deviation ω_j . In particular, we consider a linear relation of price and angular frequency deviation

$$p_j := p_\Omega - \epsilon \omega_j(t). \quad (16)$$

Linearizing the supply and demand curves around p_Ω as in equation (12) yields

$$M_j \frac{d^2 \theta_j}{dt^2} + \kappa_j \frac{d\theta_j}{dt} = S_j(p_\Omega) - D_j(p_\Omega) - \epsilon (s_j - d_j) \frac{d\theta_j}{dt} - \sum_{k=1}^N K_{jk} \sin(\theta_k - \theta_j). \quad (17)$$

By equation (13), an instantaneous economic response thus increases the *effective* damping constant to

$$\kappa_j^{\text{eff}} = \kappa_j + \epsilon (s_j - d_j) > \kappa_j. \quad (18)$$

Therefore, it always lowers the return times after perturbations, see equation (3).

4.2. Slow adaptation in discrete time steps

A second, more realistic scenario is that the Decentral Smart Grid Control is much slower than the grid dynamics. Here, we consider a discrete time control system, where the price function is the same for all nodes and given by (6). Both supply and demand are updated periodically with periodicity $T \gg \sum_j M_j / \sum_j \kappa_j$. Assuming that the grid is dynamically stable for the given parameters, the angular frequency deviation will relax to

$$\langle \omega \rangle = \frac{\Delta P}{\sum_j \kappa_j} \quad \text{with} \quad \Delta P = \sum_j S_j(p) - D_j(p). \quad (19)$$

On this basis, a new market price p' is calculated. Assuming an affine-linear price function as in equation (14) and using the linearized supply and demand curves (12), we find


$$p' - p_\Omega = -\epsilon \frac{\sum_j s_j - \sum_j d_j}{\sum_j \kappa_j} (p - p_\Omega). \quad (20)$$

This yields an oscillating dynamics of the market price, which is stable if and only if

$$\epsilon < \epsilon_{\text{cr}} = \frac{\sum_j \kappa_j}{\sum_j s_j - \sum_j d_j}, \quad (21)$$

setting a strict upper limit for the slope of the price function. The potential instability for $\epsilon > \epsilon_{\text{cr}}$ is caused by an overreaction of the suppliers and consumers to market incentives. Similar *rebound* effects can generally occur in DR systems [8], such that this problem is not specific to the current proposal.

An example for the possible dynamics of the techno-economical system is shown in figure 2 for a model grid with three generators and three consumers with values inspired by the IEEE 9-bus test grid (see panel (e)). We assume that the price elasticities



$$E_S = \left. \frac{dS_j/dp}{S_j/p} \right|_{p_\Omega} \quad \text{and} \quad E_D = \left. \frac{dD_j/dp}{D_j/p} \right|_{p_\Omega} \quad (22)$$

are the same for all nodes and given by $E_S = +0.3$ and $E_D = -0.3$ in agreement with empirical results [38–40]. The price and subsequently the demand and supply are adapted after a time step of $T = 60$ s. We assume an equilibrium price $p_\Omega = 24 \text{ ct kWh}^{-1}$ and a damping constant $\kappa_j = 0.2/s \times M_j$ with $M_j = 10^4 \text{ kgm}^2 \times \Omega$. All transmission lines have the same transmission capacity $K = 200$ MW. For these parameters, the system is stable if and only if $\epsilon < \epsilon_{cr} \approx 3 \text{ (ct/kWh)/(2}\pi \text{ Hz)}$. Otherwise the prices and the grid frequency will diverge after a small perturbation as shown in figure 2.


We note that this result can be interpreted as an application of the famous cobweb theorem from microeconomics [41] to Decentral Smart Grid Control. The generalized equilibrium condition (11) can be seen as the intersection of the loss curve $\sum_j \kappa \langle \omega \rangle$ and the net supply curve $\Delta P(\langle \omega \rangle) = \sum_j S_j(p(\langle \omega \rangle)) - D_j(p(\langle \omega \rangle))$. The loss takes the role of an effective demand function with fast relaxation, while the net supply is adapted much slower. The cobweb model then states that the economic system will relax to an equilibrium, if the slope of the loss curve is larger than the slope of the net supply curve, which yields the stability condition (21).

4.3. Delayed adaptation: risks from resonances

New risks may emerge when the Decentral Smart Grid Control acts on similar time scales as the dynamics of the grid such that the two system become truly interdependent. We first consider the case of a delayed feedback, i.e., we consider the price function (7) with $\tau \geq 0$ but without averaging ($T = 0$), i.e., consumers measure their local frequency and try to adapt as fast as possible but need their intrinsic time τ to react. To obtain analytic solutions for the interdependent techno-economical system, we use a very simple system: we linearize the supply and demand curves (12) and consider only two nodes with equal technical and economical parameters, i.e., $M_1 = M_2, \kappa_1 = \kappa_2, s_1 = s_2$ and $d_1 = d_2$. Defining our new variables as the phase difference $\Delta\theta = \theta_1 - \theta_2$ and the angular frequency difference of the two nodes $\Delta\omega = \omega_1 - \omega_2$, the equations of motion read

$$\begin{aligned} \frac{d}{dt} \Delta\theta &= \Delta\omega \\ \frac{d}{dt} \Delta\omega &= 2P - \alpha\Delta\omega - 2K \cdot \sin(\Delta\theta) - \gamma\Delta\omega_\tau, \end{aligned} \quad (23)$$

where we introduced the abbreviations $\alpha = \kappa/M, K = K_{12}/M, \gamma = \epsilon(s_1 - d_1)/M, 2P = (S_1(p_\Omega) - D_1(p_\Omega) - S_2(p_\Omega) + D_2(p_\Omega))/M$ and $\Delta\omega_\tau = \Delta\omega(t - \tau)$. In the following, time is measured in seconds, α and γ in s^{-1} and P and K in s^{-2} . This notation is similar to the one used in [19]. Delayed differential equations need a history function as initial condition, which we chose to be $\Delta\omega(t < 0) = \Delta\omega_0 \cdot (1 + 0.1 \tanh(t/2))$ for our dynamical



simulations. Furthermore, we used standard mathematica routines [42] to solve the ordinary and delayed differential equations.

The delayed adaption of supply and demand can both stabilize and destabilize the grid dynamics as shown in figure 3. The physical reason of this effect can be easily understood. The frequency-adaptive ‘effective’ power $P_{\text{eff}}(t) = 2P - \gamma\Delta\omega_\tau$ in equation (23) can be seen as a resonant driving acting on an oscillating system. Such a driving term will either damp or amplify the oscillations depending on whether the driving is in-phase or out-of-phase. The phase shift of this driving term is directly given by the delay τ , such that the stability of the system depends crucially on the value of τ . To illustrate this result, we compare the dynamics for two different values of τ in figure 3. For $\tau_1 = 0.75$ s the driving is in-phase, the oscillations are amplified and the grid becomes unstable with potentially fatal results, whereas $\tau_2 = 1.5$ s stabilizes the system.

To obtain a global view of the stability and the role of the system parameters we analyze the dynamical stability around the steady-state operation of the grid given by the fixed point


$$\left(\Delta\theta^*, \Delta\omega^*\right) = \left(\arcsin\left(\frac{P}{K}\right), 0\right). \quad (24)$$

A solution exists only if the transmission capacity is larger than the power which has to be transmitted, $K > P$ [32]. The linear stability of a dynamical system is determined by the eigenvalues of the Jacobian matrix. For a delayed system [43–45], we have to calculate the Jacobian of both the non-delayed system, based on equation (23),

$$J_0 = \begin{pmatrix} \frac{\partial}{\partial\Delta\theta} \left(\frac{d}{dt}\Delta\theta \right) & \frac{\partial}{\partial\Delta\omega} \left(\frac{d}{dt}\Delta\theta \right) \\ \frac{\partial}{\partial\Delta\theta} \left(\frac{d}{dt}\Delta\omega \right) & \frac{\partial}{\partial\Delta\omega} \left(\frac{d}{dt}\Delta\omega \right) \end{pmatrix} = \begin{pmatrix} 0 & 1 \\ -2K \cos(\Delta\theta^*) & -\alpha \end{pmatrix}, \quad (25)$$

and the derivatives for the delayed term

$$J_\tau = \begin{pmatrix} \frac{\partial}{\partial\Delta\theta_\tau} \left(\frac{d}{dt}\Delta\theta \right) & \frac{\partial}{\partial\Delta\omega_\tau} \left(\frac{d}{dt}\Delta\theta \right) \\ \frac{\partial}{\partial\Delta\theta_\tau} \left(\frac{d}{dt}\Delta\omega \right) & \frac{\partial}{\partial\Delta\omega_\tau} \left(\frac{d}{dt}\Delta\omega \right) \end{pmatrix} = \begin{pmatrix} 0 & 0 \\ 0 & -\gamma \end{pmatrix}, \quad (26)$$



where we consider exponential solutions, see [45]. The stability eigenvalues λ are then determined by the solution of the characteristic equation

$$\det(J_0 + e^{-\lambda\tau}J_\tau - \lambda\mathbb{1}) = \lambda^2 + \alpha\lambda + 2K \cos(\Delta\theta^*) + \lambda\gamma e^{-\lambda\tau} = 0. \quad (27)$$

Small perturbations induce an oscillatory motion with eigenfrequency $\text{Im}(\lambda)$ and period $2\pi/\text{Im}(\lambda)$. The amplitude grows or decreases exponentially as $e^{\text{Re}(\lambda)t}$ such that $\text{Re}(\lambda) > 0$ is the condition for a dynamic instability. This is possible only if the frequency adaption is strong enough compared to the damping of the system,

$$\text{Re}(\lambda) \geq 0 \quad \text{is possible only if} \quad \gamma \geq \alpha, \quad (28)$$

as shown below. When the delay τ changes, we observe a periodic pattern of stable and unstable parameter values as shown in figures 4 and 5. As explained above, destabilization occurs in the case of an in-phase driving which happens when τ is an integer multiple of the period of the eigenoscillations of the system.

To proof these statements we first note that $\text{Re}(\lambda) < 0$ for $\gamma = 0$ or $\tau = 0$ as long as $\alpha > 0$. We now consider the parameter values where $\text{Re}(\lambda)$ changes its sign such that the system becomes unstable. Decomposing the characteristic equation (27) into real and imaginary parts and setting $\text{Re}(\lambda) = 0$ yields the conditions

$$-\text{Im}(\lambda)^2 + 2K \cos(\Delta\theta^*) + \gamma \text{Im}(\lambda) \sin(\tau \text{Im}(\lambda)) = 0, \quad (29)$$


$$\alpha \text{Im}(\lambda) + \gamma \text{Im}(\lambda) \cos(\tau \text{Im}(\lambda)) = 0. \quad (30)$$

The second equation can be solved for τ with the result

$$\tau = \arccos(-\alpha/\gamma) + \frac{2\pi}{\text{Im}(\lambda)}n, \quad n \in \mathbb{N}. \quad (31)$$

One directly sees the periodicity in the delay τ , where the period $2\pi/\text{Im}(\lambda)$ is equal to the period of the eigenoscillations of the system. Furthermore, the $\arccos(-\alpha/\gamma)$ is real only if $\gamma \geq \alpha$, which yields a necessary condition for the destabilization by delay. Note that this statement is equivalent to the one from section 4.2, namely the damping of the system has to be larger than the price influence to always guarantee stability.

In addition to the local stability analysis, we also consider the grid dynamics after a large perturbation. We integrate the equations of motion for a long time period until $t_{\text{max}} = 600 \text{ s}$ with initial conditions randomly drawn from a subset of the phase space $Q = [-\pi, \pi] \times [-30, 30] \text{ Hz}$, see also [46], and evaluate whether the system relaxes to a stable operation, i.e., whether it converges to the fixed point (24), or not. As a criterion for stable operation we assume an angular frequency deviation of $\Delta\omega(t = t_{\text{max}}) \leq 0.1 \text{ Hz}$. The results are visualized in figure 5, panels (a)–(c), where we plot the stability in a color code (light green: stable, dark blue: unstable) as a function of the initial location in phase space for different values of τ . The results confirm the finding of the linear stability analysis. Depending on the value of τ the global stability is altered dramatically. For $\tau = 0.8 \text{ s}$ the fixed point is linearly unstable and the system does not relax for almost all initial conditions. On the contrary, a delay of $\tau = 5 \text{ s}$ leads to an almost perfect stability; the grid converges for almost all initial states. Notably, the regions of initial conditions leading to stable or unstable behavior are not clearly separated because the actual boundary of these regions has a rather complex geometric structure already in the non-delayed case.



The global stability of a fixed point of a dynamical system can be quantified by the volume of its basin of attraction. The ‘basin size’ V_{Basin} can be determined numerically using a Monte Carlo method as the ratio of initial conditions converging to a stable operation to the total number of initial conditions. Figure 5 panel (d) shows how the basin volume depends on the delay time τ in comparison to the linear stability exponent $\text{Re}(\lambda)$. As expected, V_{Basin} tends to zero in the case of linear instability, $\text{Re}(\lambda) \geq 0$. Maxima of V_{Basin} of different height are observed in the stable parameter regions, including an almost perfect stabilization for $\tau \approx 5 \text{ s}$. However, these maxima do not coincide with the minima of $\text{Re}(\lambda)$. As both the linear stability and the basin volume predict similar delays to be problematic for the system, we focus on the computationally easier to handle linear stability in the following.

4.4. Stabilization by averaging

Measuring the local grid frequency will generally take some time in a real-world system. We thus consider the dynamics of the elementary model grid for the price function (7) including both delay $\tau \geq 0$ and averaging over a period $T \geq 0$. The equation of motion for the angular frequency difference $\Delta\omega = d\Delta\theta/dt$ then reads

$$\frac{d}{dt}\Delta\omega = 2P - \alpha\Delta\omega - 2K \sin(\Delta\theta) - \frac{\gamma}{T} \int_{t-T}^t \Delta\omega(t' - \tau) dt'. \quad (32)$$

The integration can be carried out in a straightforward way by using (23) such that we obtain the modified delayed dynamical system

$$\frac{d}{dt}\Delta\omega = 2P - \alpha\Delta\omega - 2K \sin(\Delta\theta) - \frac{\gamma}{T} [\Delta\theta(t - \tau) - \Delta\theta(t - T - \tau)]. \quad (33)$$

To evaluate the stability of the steady state (24), we have to calculate the eigenvalues λ for a system with both the delay τ and the delay $\tilde{T} = T + \tau$. The Jacobian of the non-delayed system is given by (25) as above and for the delay terms only $\frac{\partial}{\partial \Delta\theta_t} \left(\frac{d}{dt}\Delta\omega \right) = -\frac{\gamma}{T}$ and $\frac{\partial}{\partial \Delta\theta_{t-\tau}} \left(\frac{d}{dt}\Delta\omega \right) = +\frac{\gamma}{T}$ are non-zero. The stability eigenvalues λ are then given by the roots of the characteristic equation [43]




Figure 6. Frequency averaging stabilizes Decentral Smart Grid Control for delayed feedback. Averaging over an interval of sufficient length T guarantees stability for all $\tau > 0$. The figure displays a scheme of the system in panel (a) and the stability exponent $\text{Re}(\lambda)$ for the system according to characteristic equation (34) as a function of delay τ as well as the averaging length T in panel (b). A transparent layer is added at $\text{Re}(\lambda) = 0$. Cuts for two different but fixed averaging times T in panel (c) and for two different but fixed delays τ in panel (d) are added. Parameters are $\gamma = 0.25 \text{ s}^{-1}$, $\alpha = 0.1 \text{ s}^{-1}$, $P = 1 \text{ s}^{-2}$ and $K = 8 \text{ s}^{-2}$ and Newton's method is used to obtain λ .

$$p(\lambda) = -\lambda^2 + \alpha\lambda + 2K\sqrt{1 - \frac{P^2}{K^2}} + \frac{\gamma}{T}(e^{-\lambda\tau} - e^{-\lambda(T+\tau)}) = 0. \quad (34)$$

Figure 6 shows the real part of the stability eigenvalue $\text{Re}(\lambda)$ as a function of the delay τ and the averaging time T . Instabilities are observed for certain values of τ , if T is small as discussed above. But for a sufficiently high T , the system stays stable regardless of the time τ . The actual values of the stability exponent $\text{Re}(\lambda)$ for large $T \gg \gamma$ are comparable to the one of the system without any price adaptation.

The results shown here are very interesting: while a delay in adaptation poses a stabilization risk to the grid, averaging the measured signal for a certain time removes the short time fluctuations that could resonantly drive the system and thereby guarantee a stable operation state. Still, the nodes can adapt to changes of the generation on all time scales slower than T , which provides an effective DR management system.

4.5. The role of the network topology


The larger the grid becomes, the more complex behavior it is able to show. Here, we consider a network with four nodes to test our results. Two consumers ($P = (S - D)/M < 0$) are supplied by two generators ($P = (S - D)/M > 0$). Each generator is coupled to a consumer to balance the power production/consumption. In addition, the generators are coupled to each other. As above we assume that all technical and economic parameters are the same for all nodes of the network. The equations of motion can be read in appendix B.

Risks from resonant driving emerge in a grid with delayed response and $T = 0$ as discussed above. The grid becomes unstable in certain regions of parameter space which are periodically spaced on the τ -axis. In a complex network, there are generally many different eigenmodes with different frequencies. The parameter regions where these modes can be excited generally overlap, such that the grid becomes unstable for most values of the delay τ as shown in the dark blue curves of panels (c), (d) in figure 7. Only for a very fast response $\tau \rightarrow 0$ the dynamic is stabilized.

We conclude that either a delayed adaption must be avoided, or alternatively, an averaging over a sufficiently long period T must be introduced as well. Figure 7 panel (b) shows the stability exponents $\text{Re}(\lambda)$ as a function of τ and T for the four-node network. Increasing T to values well above τ restores stability also for 'dangerous' values of τ as shown in the light green curves of panels (c), (d) in the figure.

5. Conclusion and outlook

In summary, we have proposed Decentral Smart Grid Control, a direct and decentralized frequency-price coupling to achieve a reliable DR in the collective network dynamics of power grids. The required information, the grid frequency, is easily accessible from everywhere in the system. As a consequence, DR via Decentral Smart



Grid Control offers a huge potential with both technical and economic benefits, in particular in grids with a large fraction of renewable sources.

First, the load information needs not be collected and evaluated centrally so that additional infrastructure for collection and for sending back central price information, is not required. This removes privacy and data security issues and should drastically lower the costs of hardware required for future power grids. The only technical device required would be a frequency meter at each customer complemented with a simple price function either programmed or implemented in hardware. Second, our results suggest that for sufficiently short feedback delays, as well as for longer delays with sufficient averaging, joint grid and economic stability is guaranteed. Stated simply, such grid would be a stable market: a stable dynamic equilibrium implies economic equilibrium. In contrast, whether joint economic and dynamic stability could be guaranteed in any other, more centralized DR setting, is, to the knowledge of the authors, yet unknown.

Decentral Smart Grid Control does need some modifications of the current system. For instance, the currently implemented strict rules for frequency regulation need to be relaxed to allow for some (small) variability, see section 3.3. Moreover, meters and price response algorithms need to be implemented at the customers' side, which might need convincing arguments. However, such decentralized control might still be much simpler to implement politically as customers need not fear data privacy issues and grid operators would not be required to install massive, network-wide and highly reliable hardware and computing power.

Generally, determining dynamic stability is typically involved for any interdependent socio-technical or techno-economic system, especially when the time scales of the system (here, the grid) and the control are similar. We have uncovered several new systemic risks in potential control options for dynamic DR in smart grids. The above results indicate that essential risks may be mastered by an appropriate design of the control in terms of decentralized and direct frequency-price coupling. This speaks for Decentral rather than Central Smart Grid Control of dynamic DRs.

We recommend to consider Decentral Smart Grid Control as a viable and possibly inexpensive alternative to central measures of DR. Since at least small and possibly unknown delays seem possible, prices should be calculated directly on the basis of a sliding average of the local grid frequency.

Acknowledgments

We thank T Walter and the Easy Smart Grid GmbH for inspiring discussions, T Ketelaer and T Pesch for help with energy market data and references. We gratefully acknowledge support from the Federal Ministry of Education and Research (BMBF grant no. 03SF0472 E [BS, DW, MT]), the Helmholtz Association (grant no. VH-NG-1025 [DW]) and the Max Planck Society [MT].

Appendix A. Swing equation

In the main part, we analyze a coarse-grained oscillator model based on the physics of coupled synchronous generators and synchronous motors, recently derived and numerically evaluated by Filatrella *et al* [17] and extended to complex networks by Rohden *et al* [18]. To achieve the large-scale network reduction, we aggregate coherent synchronous generators. Coherency of two generators means that there is no difference in their rotating angular frequency at any point in time. Together with the associated loads in that area, this coherent group is replaced by a single rotating machine with the index $j \in \{1, \dots, N\}$, which summarizes the physical properties of that group. In the language of network science, one group corresponds to one node of the network. The moment of inertia M_j of that rotating machine and its mechanical power input P_j^{mech} sum up linearly from all generators and loads of the coherent group [15]. In some groups there is more power generated than consumed such that $P_j^{\text{mech}} > 0$. If there is more power consumed than produced, we have $P_j^{\text{mech}} < 0$. The transmission network delivers power from nodes with power excess to nodes with power need.

The state of a coherent group of rotating machines is determined by its angular frequency and the rotor or power angle $\theta_j(t)$ relative to the reference axis rotating at the nominal grid angular frequency $\Omega = 2\pi \times 50$ Hz or $\Omega = 2\pi \times 60$ Hz. Correspondingly, $\omega_j = d\theta_j/dt$ gives the angular frequency deviation from the reference Ω . The dynamic is governed by the *swing equation* [15, 17, 24]

$$M_j \frac{d^2\theta_j}{dt^2} + \kappa_j \frac{d\theta_j}{dt} = P_j^{\text{mech}} - P_j^{\text{el}}, \quad (\text{A.1})$$

where P_j^{el} is the electrical power that is transmitted to or from other rotating machines and κ_j measures the damping, which is mainly provided by damper windings. (Commonly, the symbol D is used for the damping coefficient in the swing equation. In order to avoid confusion with the demand function introduced in the main text, we here use the symbol κ instead.) If the mechanical power at a node j is constantly higher than the corresponding electrical power ($\Delta P_j = P_j^{\text{mech}} - P_j^{\text{el}} > 0$), then the angular frequency deviation ω_j increases until the local mismatch in power ΔP_j dissipates due to damping. Note that all formulae use the angular frequencies while the numbers are divided by 2π for the plots to obtain frequencies.

To analyze the dynamics of the grid beyond the overall angular frequency deviation $\langle \omega \rangle := \frac{1}{N} \sum_j \omega_j$, we must take into account the details of the electrical coupling of the rotating machines along the edges of the transmission grid. The apparent power at the grid node j is given by

$$S_j = V_j \sum_{k=1}^N I_{jk}^*, \quad (\text{A.2})$$

with the complex-valued voltage V_j and the currents

$$I_{jk} = y_{jk} (V_j - V_k), \quad (\text{A.3})$$

where y_{jk} is the admittance of the transmission line between nodes j and k . In power engineering one generally uses the nodal admittance matrix Y , whose elements are defined as

$$Y_{jk} = \begin{cases} -y_{jk} & \text{for } j \neq k \\ \sum_{\ell} y_{j\ell} & j = k. \end{cases} \quad (\text{A.4})$$

The apparent power at node j is then written in the compact form

$$S_j = V_j \sum_{k=1}^N Y_{jk}^* V_k^*. \quad (\text{A.5})$$

We neglect the ohmic resistance of the transmission lines as they are typically much smaller than the shunt admittances [47], hence the admittance $Y_{jk} = iB_{jk}$ is purely imaginary. Furthermore, we assume that the magnitude of the voltage is constant throughout the grid, $|V_j| = V_0$ for all nodes $j \in \{1, \dots, N\}$. Then, the apparent power simplifies to

$$S_j = \sum_{k=1}^N V_0^2 B_{jk} \left[\sin(\theta_k - \theta_j) + i \cos(\theta_k - \theta_j) \right]. \quad (\text{A.6})$$

The electric power P_j^{el} is given by the real part of this expression. Substituting this result into the swing equation (A.1) thus yields the equations of motion

$$M_j \frac{d^2 \theta_j}{dt^2} + \kappa_j \frac{d \theta_j}{dt} = P_j^{\text{mech}}(t) - \sum_{k=1}^N V_0^2 B_{jk} \sin(\theta_k - \theta_j). \quad (\text{A.7})$$

The factor $K_{jk} := V_0^2 B_{jk}$ thus gives the maximally transmittable power between nodes k and j . Therefore, we call it the coupling strength. It is zero, if two rotating machines are not coupled along a direct transmission line.

Due to the second order term, equation (A.1) describes an oscillatory system of phase angles. As the phases oscillate, also the local angular frequency deviations $\omega(t) = d\theta_j(t)/dt$ oscillate, a phenomenon well-known in power engineering [15, 21]. In the direct neighborhood of an equilibrium point in state space the oscillations are nearly harmonic and can be decomposed into a set of eigenmodes, corresponding eigenfrequencies and corresponding eigenvectors. The eigenfrequencies depend crucially on the connectivity of the power grid. In a densely connected grid, oscillations are typically fast (> 1 Hz), while the so-called inter-area oscillations in weakly coupled grid are significantly slower. For instance, inter-area oscillations between Turkey and the rest of the European power grid with a period of up to 7 s have recently been observed [26].

We note that this model is derived from the physics of rotating machines [15], or alternatively by assuming frequency-dependent loads [24]. This description includes hydro power as well as power plants based on nuclear and fossil fuel, which dominate today's grid. It is expected that a rising penetration of renewable energy sources will decrease the effective inertia in the future, which may however be compensated by advanced power electronic devices [48]. The future development of these aspects is still under debate and beyond the scope of the present article.

Appendix B. Four node system

In section 4.5 we used a four node system. The equations of motion for this system are

$$\begin{aligned} \frac{d}{dt} \theta_j &= \Delta \omega_j \quad \text{for all } j \in \{1, \dots, 4\} \\ \frac{d}{dt} \Delta \omega_1 &= P_1 - \alpha \Delta \omega_1 + K \cdot \sin(\theta_2 - \theta_1) + K \cdot \sin(\theta_3 - \theta_1) - \frac{\gamma}{T} (\theta_{1\tau} - \theta_{1\bar{T}}) \\ \frac{d}{dt} \Delta \omega_2 &= P_2 - \alpha \Delta \omega_2 + K \cdot \sin(\theta_1 - \theta_2) - \frac{\gamma}{T} (\theta_{2\tau} - \theta_{2\bar{T}}) \\ \frac{d}{dt} \Delta \omega_3 &= P_3 - \alpha \Delta \omega_3 + K \cdot \sin(\theta_1 - \theta_3) + K \cdot \sin(\theta_4 - \theta_3) - \frac{\gamma}{T} (\theta_{3\tau} - \theta_{3\bar{T}}) \\ \frac{d}{dt} \Delta \omega_4 &= P_4 - \alpha \Delta \omega_4 + K \cdot \sin(\theta_3 - \theta_4) - \frac{\gamma}{T} (\theta_{4\tau} - \theta_{4\bar{T}}), \end{aligned} \quad (\text{B.1})$$

with $\theta_{j\tau} = \theta_j(t - \tau)$ and $\theta_{j\bar{T}} = \theta_j(t - T - \tau)$ for all j .

References

- [1] Turner J A 1999 A realizable renewable energy future *Science* **285** 687–9
- [2] Boyle G 2012 *Renewable Energy: Power for a Sustainable Future* (Oxford: Oxford University Press)
- [3] 50Hertz, Amprion, TenneT TSO and TransnetBW 2012 *Netzentwicklungsplan Strom*, online at <http://www.netzentwicklungsplan.de> (retrieved 7/8/2014)
- [4] Heide D, von Bremen L, Greiner M, Hoffmann C, Speckmann M and Bofinger S 2010 Seasonal optimal mix of wind and solar power in a future, highly renewable Europe *Renew. Energy* **35** 2483–9
- [5] Milan P, Wächter M and Peinke J 2013 Turbulent character of wind energy *Phys. Rev. Lett.* **110** 138701
- [6] Butler D 2007 Energy efficiency: super savers: meters to manage the future *Nature* **445** 586–8
- [7] Albadi M H and El-Saadany E F 2008 A summary of demand response in electricity markets *Electr. Power Syst. Res.* **78** 1989–96
- [8] Palensky P and Dietrich D 2011 Demand side management: demand response, intelligent energy systems, and smart loads *IEEE Trans. Ind. Inform.* **7** 381–8
- [9] Kok J K, Warmer C J and Kamphuis I G 2005 The powermatcher: multiagent control of electricity demand and supply *Proc. AAMAS'05 (Utrecht)* pp 75–82
- [10] Ericsson G N 2010 Cyber security and power system communication—essential parts of a smart grid infrastructure *IEEE Trans. Power Deliv.* **25** 1501–7
- [11] Fang X, Misra S, Xue G and Yang D 2012 Smart grid—the new and improved power grid: a survey *IEEE Commun. Surv. Tutorials* **14** 944–80
- [12] Buldyrev S V, Parshani R, Paul G, Stanley H E and Havlin S 2010 Catastrophic cascade of failures in interdependent networks *Nature* **464** 1025–8
- [13] Schweppe F C 1982 Frequency adaptive power-energy re-scheduler *US Patent* 4317049
- [14] Short J A, Infield D G and Freris L L 2007 Stabilization of grid frequency through dynamic demand control *IEEE Trans. Power Syst.* **22** 1284–93
- [15] Machowski J, Bialek J and Bumby J 2008 *Power System Dynamics, Stability and Control* (New York: Wiley)
- [16] Walter T 2014 *VDE Mitgliederinformationen* 2014 64 online at <http://www.vde.com/de/fg/ETG/Pbl/MI/2014-01/Seiten/Homepage.aspx> (retrieved 7/8/2014)

- [17] Filatrella G, Nielsen A H and Pedersen N F 2008 Analysis of a power grid using a Kuramoto-like model *Eur. Phys. J. B* **61** 485–91
- [18] Rohden M, Sorge A, Timme M and Witthaut D 2012 Self-organized synchronization in decentralized power grids *Phys. Rev. Lett.* **109** 064101
- [19] Rohden M, Sorge A, Witthaut D and Timme M 2014 Impact of network topology on synchrony of oscillatory power grids *Chaos* **24** 013123
- [20] Witthaut D and Timme M 2012 Braess's paradox in oscillator networks, desynchronization and power outage *New J. Phys.* **14** 083036
- [21] Dörfler F, Chertkov M and Bullo F 2013 Synchronization in complex oscillator networks and smart grids *Proc. Natl Acad. Sci.* **110** 2005–10
- [22] Motter A E, Myers S A, Anghel M and Nishikawa T 2013 Spontaneous synchrony in power-grid networks *Nat. Phys.* **9** 191–7
- [23] Menck P J, Heitzig J, Kurths J and Schellnhuber H J 2014 How dead ends undermine power grid stability *Nat. Commun.* **5** 3969
- [24] Bergen A R and Hill D J 1981 A structure preserving model for power system stability analysis *Trans. Power App. Syst.* **PAS-100** 25–35
- [25] Strbac G 2008 Demand side management: benefits and challenges *Energy Policy* **36** 4419–26
- [26] Tor O B, Gencoglu C, Tamdir O, Cebeci M E and Güven N 2011 Investigation of necessary transmission enforcements at the Balkan region of ENTSO/E in the sense of inter-area oscillations after interconnection of Turkey *7th Int. Conf. on Electrical and Electronics Engineering (Bursa)* pp 1–7
- [27] For instance, such a system is mandatory for all newly installed devices in Germany since 1.7.2012, see VDE Anwendungsregel VDE-AR-N 4105, online at <http://vde.com/de/fnn/arbeitsgebiete/seiten/n4105.aspx> (retrieved 7/8/2014)
- [28] Zhong Z, Xu C, Billian B J, Zhang L, Tsai S S, Connors R W, Centeno V A, Phadke A G and Liu Y 2005 Power system frequency monitoring network (FNET) implementation *IEEE Trans. Power Syst.* **20** 1914–21
- [29] Borenstein S 2005 The long-run efficiency of real-time electricity pricing *Energy J.* **26** 93–116
- [30] Farhangi H 2010 The path of the smart grid *IEEE Power Energy Mag.* **8** 18–28
- [31] van Renssen S 2014 People power to the rescue *Nat. Clim. Change* **4** 417–9
- [32] Manik D, Witthaut D, Schäfer B, Matthiae M, Sorge A, Rohden M, Katifori E and Timme M 2014 Supply networks: instabilities without overload *Eur. Phys. J. ST* **223** 2527–47
- [33] Subbarao D, Uma R, Saha B and Phanendra M V R 2001 Self-organization on a power system *IEEE Power Eng. Rev.* **21** 59–62
- [34] Kirby B J, Dyer J, Shoureshi R A, Guttromson R and Dagle J 2002 Frequency control concerns in the north american electric power system *Technical Report for the U.S. Department of Energy*, online at <http://dx.doi.org/10.2172/885842> (retrieved 7/8/2014) doi:10.2172/885842
- [35] *Continental Europe Operation Handbook* 2014 European Network of Transmission System Operators for Electricity www.entsoe.eu/publications/system-operations-reports/operation-handbook
- [36] Historical data for the Power Spot Market at the European Energy Exchange (EEX), <http://www.eex.com/en/market-data>
- [37] Bashan A, Berezin Y, Buldyrev S V and Havlin S 2013 The extreme vulnerability of interdependent spatially embedded networks *Nat. Phys.* **9** 667–72
- [38] Green R J and Newbery D M 1992 Competition in the British electricity spot market *JPE* **100** 929–53
- [39] Samyn N 2010 Empirical analysis of price-curves at the EEX *Master Thesis* University of St. Gallen, Switzerland
- [40] Faruqui A and George S S 2002 The value of dynamic pricing in mass markets *TEJ* **15** 45–55
- [41] Ezekiel M 1938 The cobweb theorem *QJE* **52** 255–80
- [42] Wolfram Research Inc. 2012 *Mathematica* Version 9.0 www.wolfram.com/mathematica
- [43] Roussel M R 2005 Delay-differential equations online at people.uleth.ca/~roussel/nld/delay.pdf (retrieved 7/8/2014)
- [44] Forde J and Nelson P 2004 Applications of sturm sequences to bifurcation analysis of delay differential equation models *J. Math. Anal. Appl.* **300** 273–84
- [45] Driver R D 1977 *Ordinary and Delay Differential Equations* (New York: Springer)
- [46] Menck P J, Heitzig J, Marwan N and Kurths J 2013 How basin stability complements the linear-stability paradigm *Nat. Phys.* **9** 89–92
- [47] van Hertem D, Verboomen J, Purchala K, Belmans R and Kling W L 2006 Usefulness of DC power flow for active power flow analysis with flow controlling devices *8th IEEE Int. Conf. on AC and DC Power Transmission (28–31 March 2006)*
- [48] Trovato V, Tindemans S H and Strbac G 2013 Demand response contribution to effective inertia for system security in the GB 2020 gone green scenario *4th IEEE PES Innovative Smart Grid Technologies Europe (ISGT Europe) (October 6–9, Copenhagen)* pp 1–5